

【添付資料12：浸出水処理施設電力量】

共 通 月 報

須賀川地方衛生センター
浸出水処理施設

2014年 3月



日 付	ご み 焼 却 量			電 力 量								用 水 使 用 量				灯 油 使用量	消石灰 使用量	キレー 使用量	運転時間	
	1号炉	2号炉	合 計	電力 kWh	プラント 動力 kWh	建 築 動力 kWh	照明 kWh	管理棟 動力 kWh	管理棟 照明 kWh	排ガス 高度処理 施設 kWh	浸出水 処理 施設 kWh	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t		kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3	リットル	kg	リットル	H	H
1	11.250	10.490	21.740	5030	3250	120	170	0	190	1050	420	0	86	0	2	394	235	43.3	5.8	5.8
2	0.000	0.000	0.000	2390	1740	110	60	0	120	60	430	0	0	0	2	0	0	4.8	0.0	0.0
3	0.000	38.380	38.380	5156	3360	180	290	180	260	720	600	3	87	1	2	433	268	20.7	0.0	13.5
4	0.000	67.850	67.850	6776	4470	180	370	130	410	1120	590	3	179	1	0	0	480	42.5	0.0	24.0
5	0.000	67.160	67.160	6760	4530	180	380	130	330	1110	510	2	184	0	1	0	480	42.9	0.0	24.0
6	4.520	67.490	72.010	7048	4580	170	380	110	390	1240	630	2	199	1	1	550	490	40.9	0.6	24.0
7	67.190	66.920	134.110	9472	6120	190	360	180	400	2250	520	2	307	0	0	73	960	62.3	24.0	24.0
8	14.100	14.150	28.250	5432	3510	140	170	180	260	1110	500	0	84	0	2	318	274	35.9	6.9	6.6
9	0.000	0.000	0.000	2628	1960	110	60	60	120	50	460	0	0	0	3	0	0	4.8	0.0	0.0
10	40.080	0.000	40.080	5248	3380	180	280	150	280	790	600	3	65	1	2	630	270	22.5	13.6	0.0
11	66.460	0.000	66.460	6840	4270	330	360	180	400	1240	600	3	211	1	1	0	480	41.8	24.0	0.0
12	67.800	0.000	67.800	7100	4440	480	350	120	370	1310	480	2	185	1	1	301	480	42.3	24.0	0.0
13	65.840	68.930	134.770	9708	6190	190	380	70	380	2320	580	2	346	1	1	513	949	69.9	24.0	23.6
14	67.920	68.190	136.110	9328	5960	210	350	150	290	2320	460	3	316	0	1	0	960	79.1	24.0	24.0
15	14.220	14.250	28.470	5302	3380	190	200	0	220	1110	410	0	231	1	2	638	287	36.4	7.2	7.0
16	0.000	0.000	0.000	2366	1740	120	60	0	110	50	400	0	0	0	2	0	0	4.8	0.0	0.0
17	0.000	41.210	41.210	4972	3360	170	250	150	330	690	480	3	110	0	2	742	272	20.8	0.0	13.7
18	0.000	66.650	66.650	6776	4590	170	350	140	340	1070	560	3	197	2	0	0	480	39.3	0.0	24.0
19	63.510	66.930	130.440	9320	6090	170	360	30	330	2140	530	1	384	1	0	281	926	63.4	22.4	24.0
20	62.040	66.980	129.020	9436	6120	170	360	110	410	2180	550	3	356	0	1	0	960	65.9	24.0	24.0
21	59.390	61.530	120.920	9160	5950	180	360	70	370	2250	400	0	338	0	0	0	960	61.5	24.0	24.0
22	6.720	6.540	13.260	4504	2980	120	150	0	220	850	390	1	46	0	2	346	186	39.2	4.6	4.6
23	0.000	0.000	0.000	2256	1730	100	60	0	130	50	310	0	0	0	2	0	0	4.8	0.0	0.0
24	39.210	0.000	39.210	4668	3100	170	250	100	260	730	410	2	92	1	1	504	263	29.6	13.2	0.0
25	66.430	16.120	82.550	6884	4570	160	330	30	370	1500	300	2	237	1	0	450	581	43.2	24.0	5.2
26	66.290	67.190	133.480	9410	6230	160	320	40	370	2260	390	1	401	1	0	0	953	70.8	24.0	24.0
27	64.320	66.550	130.870	9450	6090	160	350	50	330	2290	540	2	353	0	1	0	960	68.1	24.0	24.0
28	62.630	65.880	128.520	9482	6150	140	340	50	280	2290	520	2	378	1	0	0	960	76.0	24.0	24.0
29	13.330	13.970	27.300	5218	3420	140	140	80	190	1110	400	0	94	0	0	407	276	39.4	6.8	6.9
30	0.000	0.000	0.000	2358	1710	120	70	80	190	50	410	1	0	0	2	72	0	4.8	0.0	0.0
31	0.000	40.230	40.230	5270	3640	150	250	30	260	670	540	2	94	1	1	398	272	24.0	0.0	13.7
最 大	67.920	68.930	136.850	9708	6230	480	380	180	410	2320	630	3	401	2	3	742	960	79.1	24.0	24.0
最 小	0.000	0.000	0.000	2256	1710	100	60	0	110	50	300	0	0	0	0	0	0	4.8	0.0	0.0
平 均	29.782	34.310	64.092	6314	4149	173	263	84	287	1225	481	2	179	1	1	227	473	40.2	11.1	12.5
合 計	923.250	1063.600	1986.850	195748	128610	5360	8160	2600	8910	37980	14920	48	5560	16	35	7050	14662	1245.7	345.2	388.5

1号炉運転日数	19 日
2号炉運転日数	22 日

共 通 月 報

須賀川地方衛生センター
ごみ処理施設

2014年 4月

日 付	ご み 焼 却 量			電 力 量								用 水 使 用 量				灯 油 使用量 リットル	消石灰 使用量 kg	キレート 使用量 リットル	運転時間	
	1号炉	2号炉	合 計	電力量	プラント 動力	建 築 動力	照明	管理棟 動力	管理棟 照 明	排ガス 高度処理 施設	浸出水 処 理 施設	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t	kWh	kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3				H	H
1	0.000	67.870	67.870	6618	4480	150	320	50	260	1170	460	3	194	1	0	269	480	41.1	0.0	24.0
2	66.930	67.220	134.150	9472	6170	140	340	50	200	2250	540	1	382	1	0	269	952	61.5	23.7	24.0
3	63.310	65.440	128.750	9326	6100	140	330	0	210	2230	480	3	373	0	0	0	960	68.4	24.0	24.0
4	64.960	66.390	131.350	9232	6110	140	310	0	230	2200	450	3	385	1	0	0	960	80.8	24.0	24.0
5	13.040	12.840	25.880	5280	3470	120	160	0	130	1100	410	0	94	0	1	415	269	34.4	6.6	6.7
6	0.000	0.000	0.000	2624	2000	110	60	0	130	50	420	0	0	0	2	0	0	4.8	0.0	0.0
7	39.140	0.000	39.140	5236	3470	150	250	70	350	750	580	2	81	2	1	433	265	26.0	13.4	0.0
8	66.680	0.000	66.680	6700	4390	170	340	20	230	1200	580	3	208	1	1	0	480	43.2	24.0	0.0
9	66.490	25.960	92.450	7800	5140	150	320	30	220	1630	520	2	260	1	0	337	643	49.3	24.0	8.3
10	65.900	66.910	132.810	9664	6250	150	340	50	230	2290	600	2	386	0	0	0	1117	76.4	24.0	24.0
11	66.300	67.350	133.650	9466	6110	160	330	80	240	2300	520	4	377	2	1	0	1210	79.2	24.0	24.0
12	14.100	14.070	28.170	5558	3550	130	160	120	130	1170	530	0	94	0	1	460	312	36.4	7.0	7.0
13	0.000	0.000	0.000	2634	1880	120	60	180	120	50	540	0	0	0	2	0	0	4.8	0.0	0.0
14	38.730	0.000	38.730	5054	3260	170	250	140	220	740	610	2	91	1	2	410	264	24.7	13.3	0.0
15	65.870	48.580	114.450	9048	5710	360	370	60	280	2000	580	4	334	1	2	439	809	58.1	24.0	16.6
16	66.600	58.410	125.010	10140	6370	540	360	0	270	2260	550	2	375	1	1	161	936	71.6	24.0	23.1
17	66.360	38.140	104.500	8370	5350	150	350	0	260	1930	570	3	273	1	2	279	733	49.0	24.0	12.8
18	66.200	67.390	133.590	9592	6270	130	350	10	270	2300	490	4	386	1	1	0	960	62.6	24.0	24.0
19	14.110	14.350	28.460	5442	3500	120	190	0	220	1130	500	0	97	0	2	313	278	37.5	6.8	7.0
20	0.000	0.000	0.000	2544	1830	100	60	0	140	50	500	0	0	0	3	0	0	4.8	0.0	0.0
21	0.000	38.050	38.050	5296	3540	160	280	50	220	720	590	3	92	1	2	465	255	15.2	0.0	12.9
22	55.220	65.560	120.780	9176	5960	170	370	0	400	2140	490	3	336	1	1	367	867	50.1	19.4	24.0
23	64.580	66.010	130.590	9816	6360	290	340	10	340	2300	480	2	360	0	1	0	793	55.7	24.0	24.0
24	62.060	63.960	126.020	9554	6200	130	320	0	210	2320	570	2	362	1	0	0	666	50.5	24.0	24.0
25	61.230	62.260	123.490	9470	6150	140	340	0	230	2300	480	3	323	2	1	0	519	56.7	24.0	24.0
26	13.300	14.090	27.390	5472	3530	110	170	0	140	1170	490	0	98	0	2	466	141	31.5	7.0	7.1
27	0.000	0.000	0.000	2472	1770	110	60	0	130	50	490	0	0	0	2	0	0	4.8	0.0	0.0
28	39.860	0.000	39.860	4980	3240	120	300	0	270	720	570	3	90	1	2	331	183	26.1	13.3	0.0
29	65.350	0.000	65.350	6644	4410	130	340	0	190	1190	540	1	206	0	0	0	240	31.7	24.0	0.0
30	66.040	54.870	120.910	8932	5850	130	320	0	220	2130	480	2	352	1	1	510	426	46.6	24.0	18.7
31																				
最 大	66.930	67.870	134.150	10140	6370	540	370	180	400	2320	610	4	386	2	3	510	1210	80.8	24.0	24.0
最 小	0.000	0.000	0.000	2472	1770	100	60	0	120	50	410	0	0	0	0	0	0	4.8	0.0	0.0
平 均	42.412	34.857	77.269	7054	4614	163	270	31	223	1461	520	2	220	1	1	197	524	42.8	15.7	12.8
合 計	1272.360	1045.720	2318.080	211612	138420	4890	8090	920	6690	43840	15610	57	6609	21	34	5924	15718	1283.5	470.4	384.0

1号炉運転日数	24 日
2号炉運転日数	21 日

共 通 月 報

須賀川地方衛生センター
ごみ処理施設

2014年 5月

日 付	ご み 焼 却 量			電 力 量								用 水 使 用 量				灯 油 使用量	消石灰 使用量	キレート 使用量	運転時間	
	1号炉	2号炉	合 計	電力量	プラント 動力	建 築 動力	照明	管理棟 動力	管理棟 照 明	排ガス 高度処理 施設	浸出水 処 理 施設	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t	kWh	kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3	リットル	kg	リットル	H	H
1	63.300	66.190	129.490	9612	6270	130	360	0	200	2240	560	2	390	1	0	0	505	53.5	24.0	24.0
2	65.560	66.360	131.920	9452	6170	130	340	0	260	2260	510	4	365	1	0	0	480	58.9	24.0	24.0
3	14.070	13.550	27.620	5328	3450	110	150	0	130	1120	480	0	99	0	2	411	139	32.7	6.9	6.8
4	0.000	0.000	0.000	2440	1750	100	70	0	120	50	490	0	0	0	2	0	0	4.8	0.0	0.0
5	0.000	37.560	37.560	4862	3280	120	220	0	170	650	560	0	83	0	1	399	126	14.4	0.0	12.7
6	7.030	67.580	74.610	6830	4540	130	330	0	160	1310	490	1	205	1	1	616	254	30.1	1.5	24.0
7	66.740	68.560	135.300	9648	6290	130	330	0	230	2290	570	2	353	1	0	0	480	46.1	24.0	24.0
8	66.590	66.650	133.240	9582	6290	130	320	0	210	2260	540	2	396	0	0	0	488	50.8	24.0	24.0
9	65.980	66.990	132.970	9266	6010	130	350	0	240	2260	480	3	370	2	0	0	960	58.0	24.0	24.0
10	10.620	14.150	24.770	5092	3380	110	140	0	130	980	470	0	91	0	1	467	276	29.4	6.9	6.8
11	0.000	0.000	0.000	2424	1750	110	60	0	130	50	460	0	0	0	3	0	0	4.8	0.0	0.0
12	0.000	39.490	39.490	5218	3620	110	290	0	230	640	540	3	106	1	1	362	259	19.0	0.0	13.1
13	0.000	68.660	68.660	6542	4340	130	400	0	210	1100	540	3	176	1	0	0	480	25.9	0.0	24.0
14	0.000	69.390	69.390	6176	3960	300	350	0	230	1080	450	2	198	1	1	0	480	26.6	0.0	24.0
15	0.000	69.210	69.210	6404	3840	550	380	0	240	1080	520	3	177	1	0	0	480	29.2	0.0	24.0
16	0.000	69.720	69.720	6228	4000	260	390	0	230	1090	460	4	181	1	0	0	480	24.5	0.0	24.0
17	0.000	70.850	70.850	6532	4500	130	290	0	150	1110	470	1	181	0	0	0	480	24.0	0.0	24.0
18	0.000	70.800	70.800	6528	4510	120	300	0	160	1110	450	0	177	0	0	0	480	24.7	0.0	24.0
19	15.300	68.230	83.530	7404	4960	130	310	0	230	1430	540	3	198	1	1	489	571	24.3	4.6	24.0
20	67.410	67.050	134.460	9302	6130	130	330	0	210	2220	460	3	367	1	0	0	960	49.5	24.0	24.0
21	66.870	68.130	135.000	9562	6290	130	340	0	230	2230	530	1	368	1	0	0	960	52.3	24.0	24.0
22	66.320	68.320	134.640	9504	6220	130	330	0	220	2240	540	2	360	1	0	0	960	55.3	24.0	24.0
23	15.530	68.490	84.020	7694	5020	130	350	0	250	1690	470	4	221	1	0	175	627	43.0	7.3	24.0
24	0.000	14.290	14.290	3974	2670	110	220	0	150	510	450	0	46	0	0	263	142	17.5	0.0	7.0
25	0.000	0.000	0.000	2748	2060	110	90	0	130	50	450	1	0	0	1	0	0	4.8	1.6	0.0
26	40.450	0.000	40.450	5544	3880	120	310	0	210	700	520	3	104	1	0	285	263	20.0	13.3	0.0
27	67.040	0.000	67.040	6660	4250	380	350	0	230	1140	510	2	163	1	2	0	480	43.7	24.0	0.0
28	69.170	0.000	69.170	6490	4070	470	350	0	200	1140	430	2	181	1	2	0	480	37.9	24.0	0.0
29	68.080	0.000	68.080	6486	4500	110	400	0	240	1130	320	5	196	1	2	0	480	43.7	24.0	0.0
30	69.790	17.830	87.620	7368	4850	280	350	390	240	1410	430	6	209	2	2	419	580	38.6	24.0	5.1
31	72.130	72.100	144.230	9370	6190	410	310	0	160	2200	220	2	345	0	0	0	960	53.9	24.0	24.0
最 大	72.130	72.100	144.230	9648	6290	550	400	390	260	2290	570	6	396	2	3	616	960	58.9	24.0	24.0
最 小	0.000	0.000	0.000	2424	1750	100	60	0	120	50	220	0	0	0	0	0	0	4.8	0.0	0.0
平 均	31.548	44.198	75.746	6783	4485	180	294	13	198	1315	481	2	203	1	1	125	462	33.6	11.4	15.6
合 計	977.980	1370.150	2348.130	210270	139040	5570	9110	390	6130	40770	14910	64	6306	22	22	3886	14310	1041.9	354.1	483.4

1号炉運転日数	20 日
2号炉運転日数	24 日

共 通 月 報

須賀川地方衛生センター
ごみ処理施設

2014年 6月

日付	ごみ焼却量			電 力 量								用 水 使 用 量				灯油 使用量 リットル	消石灰 使用量 kg	キレート 使用量 リットル	運転時間	
	1号炉	2号炉	合 計	電力量	プラント 動力	建 築 動力	照明	管理棟 動力	管理棟 照 明	排ガス 高度処理 施設	浸出水 処 理 施設	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t	kWh	kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3				H	H
1	13.990	14.640	28.630	5420	3550	150	150	0	150	1300	260	0	103	0	1	436	294	36.1	7.2	7.3
2	38.210	42.060	80.270	7326	4620	640	290	440	220	1300	470	5	202	1	2	759	526	30.8	12.4	14.1
3	66.390	65.970	132.360	10348	6440	1080	360	420	240	2210	210	4	399	2	0	0	960	63.7	24.0	24.0
4	65.540	66.470	132.010	10192	6360	890	350	490	280	2190	330	4	380	1	0	0	960	49.4	24.0	24.0
5	65.790	67.210	133.000	9912	6250	650	360	260	220	2230	390	5	384	1	0	0	1119	55.1	24.0	24.0
6	67.630	68.200	135.830	9536	6030	560	310	310	220	2230	350	3	347	1	0	0	1205	54.4	24.0	24.0
7	14.120	14.440	28.560	5498	3470	210	160	0	140	1210	440	0	102	0	0	398	287	40.2	6.5	7.2
8	0.000	0.000	0.000	2506	1900	50	60	0	140	50	460	0	0	0	1	0	0	0	4.8	0.0
9	39.990	15.570	55.560	5864	3840	180	260	250	220	1000	550	3	101	1	2	908	353	26.3	13.3	4.6
10	66.490	67.310	133.800	9944	6320	510	320	580	210	2210	540	4	339	1	0	0	960	58.7	24.0	24.0
11	68.040	68.620	136.660	9916	6250	640	320	230	210	2210	460	3	345	1	0	0	960	51.6	24.0	24.0
12	67.880	68.900	136.780	9900	6180	630	310	10	210	2200	550	3	314	1	0	219	960	52.0	24.0	24.0
13	68.070	68.480	136.550	9668	6140	470	310	300	220	2170	530	4	321	1	0	0	960	57.9	24.0	24.0
14	14.140	14.730	28.870	5512	3510	160	170	0	130	1210	450	0	72	0	0	385	290	34.6	7.2	7.2
15	0.000	0.000	0.000	2372	1770	50	60	0	130	50	460	0	0	0	3	0	0	4.8	0.0	0.0
16	0.000	40.860	40.860	5458	3460	600	230	710	210	680	460	3	85	1	1	326	273	24.6	0.0	13.7
17	66.950	67.170	134.120	10362	6370	960	330	420	220	2200	470	5	334	1	0	340	938	49.4	23.0	24.0
18	66.030	68.330	134.360	9834	6280	670	320	560	230	2190	340	3	326	1	0	0	960	55.4	24.0	24.0
19	64.730	66.620	131.350	9544	6220	470	280	370	210	2190	330	4	297	1	1	0	960	53.5	24.0	24.0
20	66.790	68.150	134.940	9536	6210	510	310	220	240	2200	270	4	324	1	0	0	960	58.4	24.0	24.0
21	13.870	13.400	27.270	5872	3480	130	160	0	170	1760	330	0	85	0	0	373	285	33.8	7.3	6.8
22	0.000	0.000	0.000	3670	2250	50	60	0	140	1080	240	0	0	0	2	0	0	4.8	0.0	0.0
23	37.880	0.000	37.880	5978	3730	520	270	550	210	1060	360	4	83	1	2	356	260	29.2	13.1	0.0
24	68.430	0.000	68.430	7126	4620	750	320	400	230	1150	240	4	154	1	0	0	480	35.5	24.0	0.0
25	67.030	0.000	67.030	7274	4670	700	320	420	230	1140	400	3	194	1	1	0	480	38.4	24.0	0.0
26	67.450	0.000	67.450	7224	4610	710	320	310	240	1150	390	4	178	1	2	0	480	38.3	24.0	0.0
27	67.980	0.000	67.980	7048	4580	720	310	410	240	1140	260	4	150	2	2	0	480	42.7	24.0	0.0
28	67.700	0.000	67.700	6876	4500	800	290	0	150	1150	290	1	160	0	2	0	480	41.8	24.0	0.0
29	66.600	0.000	66.600	7162	4510	890	290	0	160	1150	480	1	180	0	2	0	480	36.9	24.0	0.0
30	65.440	0.000	65.440	7442	4670	670	320	320	230	1150	570	4	176	1	2	0	480	44.0	24.0	0.0
31																				
最大	68.430	68.900	136.780	10362	6440	1080	360	710	280	2230	570	5	399	2	3	908	1205	63.7	24.0	24.0
最小	0.000	0.000	0.000	2372	1770	50	60	0	130	50	210	0	0	0	0	0	0	4.8	0.0	0.0
平均	48.105	32.238	80.343	7478	4760	521	264	266	202	1505	396	3	205	1	1	150	594	40.2	17.4	11.6
合計	1443.160	967.130	2410.290	224330	142810	15620	7920	7980	6050	45160	11880	82	6135	23	25	4500	17830	1207.1	521.9	349.0

1号炉運転日数	26 日
2号炉運転日数	19 日

共 通 月 報

須賀川地方衛生センター
ごみ処理施設

2014年 7月

日 付	ご み 焼 却 量			電 力 量								用 水 使 用 量				灯 油 使用量	消石灰 使用量	キレート 使用量	運転時間	
	1号炉	2号炉	合 計	電力量	プラント 動 力	建 築 動 力	照明	管理棟 動 力	管理棟 照 明	排ガス 高度処理 施設	浸出水 処 理 施設	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t	kWh	kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3				リットル	kg
1	67.000	0.000	67.000	7750	4640	730	330	440	240	1430	570	5	153	1	1	529	480	44.0	24.0	0.0
2	66.470	70.470	136.940	9676	5890	730	340	430	220	2190	490	4	339	1	0	418	950	61.2	24.0	23.6
3	64.740	65.620	130.360	9918	6030	780	330	510	230	2160	570	5	330	2	0	0	960	69.6	24.0	24.0
4	63.650	64.200	127.850	9892	6040	740	320	0	230	2190	560	3	311	1	1	0	960	69.6	24.0	24.0
5	12.910	12.910	25.820	5644	3520	270	160	0	140	1210	480	0	69	0	1	871	297	43.8	7.6	7.1
6	0.000	0.000	0.000	2588	1940	50	80	0	140	50	480	0	0	0	2	0	0	4.8	0.0	0.0
7	0.000	36.830	36.830	5372	3470	480	250	380	250	650	490	4	84	1	2	334	252	18.2	0.0	12.7
8	60.670	65.950	126.620	9962	5910	1030	310	610	240	2120	530	5	309	1	0	488	912	65.5	21.7	24.0
9	50.820	53.980	104.800	8362	5140	650	310	90	220	1810	430	3	227	1	0	197	745	53.4	18.9	18.5
10	62.040	65.340	127.380	10320	6110	1130	290	550	240	2170	590	5	284	1	0	0	960	52.6	24.0	24.0
11	62.210	66.720	128.930	9944	6180	730	320	780	240	2140	530	5	307	1	0	0	960	68.3	24.0	24.0
12	13.320	13.580	26.900	5328	3390	180	140	0	160	1110	500	0	89	0	0	249	283	35.2	7.2	6.8
13	0.000	0.000	0.000	2416	1750	50	60	0	170	40	510	0	0	0	0	0	0	4.8	0.0	0.0
14	38.680	0.000	38.680	5788	3660	590	230	710	240	700	600	5	61	2	1	483	257	32.4	13.0	0.0
15	64.810	18.120	82.930	8304	5050	860	320	810	240	1440	580	6	188	1	0	564	583	49.7	24.0	5.3
16	63.520	68.390	131.910	10128	6240	830	290	730	230	2190	520	3	347	1	0	0	960	60.0	24.0	24.0
17	61.740	66.860	128.600	10136	6200	800	310	590	240	2210	590	5	300	1	0	0	960	56.2	24.0	24.0
18	64.140	68.070	132.210	10172	6260	780	300	590	280	2220	570	5	312	2	0	0	960	72.4	24.0	24.0
19	13.310	13.300	26.610	5580	3550	300	140	0	170	1070	510	0	79	0	0	551	301	34.7	7.5	7.4
20	0.000	0.000	0.000	2456	1810	40	70	0	150	40	510	0	0	0	0	0	0	4.8	0.0	0.0
21	0.000	38.710	38.710	5360	3390	570	230	410	200	630	510	2	63	0	0	354	249	27.8	0.0	12.6
22	51.680	67.680	119.360	9664	5750	930	320	700	220	2020	610	5	274	1	0	478	852	63.3	18.7	24.0
23	60.700	68.170	128.870	10820	6450	1320	320	1170	230	2170	520	4	303	1	0	0	960	60.3	24.0	24.0
24	59.280	66.850	126.130	10755	6410	1310	310	1050	260	2170	520	4	313	1	1	0	960	70.4	24.0	24.0
25	61.190	67.150	128.340	10576	6260	1280	310	720	230	2180	520	7	292	2	0	0	960	67.7	24.0	24.0
26	14.040	14.040	28.080	6332	3650	460	150	0	160	1560	500	2	101	0	0	641	302	41.2	7.8	7.1
27	0.000	0.000	0.000	3980	2190	110	70	0	150	1100	500	0	0	0	0	0	0	4.8	0.0	0.0
28	0.000	39.560	39.560	6848	3660	810	250	860	220	1490	620	5	82	1	0	341	263	20.7	0.0	13.3
29	0.000	67.070	67.070	7660	4570	1130	320	690	220	1020	570	6	185	1	0	0	480	36.2	0.0	24.0
30	0.000	67.320	67.320	7856	4620	1300	320	1330	230	960	600	5	182	1	0	0	480	30.5	0.0	24.0
31	0.000	66.830	66.830	8192	4670	1530	310	980	230	1030	610	5	160	2	0	0	480	27.5	0.0	24.0
最 大	67.000	70.470	136.940	10820	6450	1530	340	1330	280	2220	620	7	347	2	2	871	960	72.4	24.0	24.0
最 小	0.000	0.000	0.000	2416	1750	40	60	0	140	40	430	0	0	0	0	0	0	4.8	0.0	0.0
平 均	34.739	42.378	77.117	7670	4658	726	252	488	214	1467	538	3	185	1	0	210	573	43.6	13.4	15.3
合 計	1076.920	1313.720	2390.640	237780	144400	22500	7810	15130	6620	45470	16690	108	5744	27	9	6498	17766	1351.6	414.3	474.3

1号炉運転日数	21 日
2号炉運転日数	25 日

共 通 月 報

須賀川地方衛生センター
ごみ焼却処理施設

2014年 8月

日 付	ご み 焼 却 量			電 力 量								用 水 使 用 量				灯 油 使用量	消石灰 使用量	キレート 使用量	運転時間	
	1号炉	2号炉	合 計	電力量	プラント 動力	建 築 動力	照明	管理棟 動力	管理棟 照 明	排ガス 高度処理 施設	浸出水 処 理 施設	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t	kWh	kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3	リットル	kg	リットル	H	H
1	24.740	68.670	93.410	8796	5130	1230	320	1300	250	1490	580	6	213	2	0	596	641	32.2	8.2	24.0
2	63.210	67.990	131.200	10080	6160	1080	290	0	180	2040	470	2	309	0	0	0	960	60.6	24.0	24.0
3	14.070	14.040	28.110	5884	3700	440	150	0	160	1090	490	0	87	0	0	926	316	40.6	8.2	7.5
4	37.060	30.570	67.630	7168	4200	920	250	1120	220	1190	590	5	126	1	1	738	449	25.9	13.8	9.8
5	61.640	68.070	129.710	10596	6210	1290	340	1550	240	2140	580	6	336	2	0	0	960	53.0	24.0	24.0
6	58.470	67.220	125.690	11144	6490	1670	330	1270	320	2140	490	5	362	2	0	0	960	66.0	24.0	24.0
7	57.890	67.330	125.220	10816	6280	1440	300	1570	230	2160	590	6	322	1	0	0	960	66.3	24.0	24.0
8	61.180	66.150	127.330	10380	5980	1280	320	1880	240	2200	560	5	309	2	0	165	1112	66.2	24.0	24.0
9	12.660	13.230	25.890	5740	3570	410	150	0	150	1110	490	0	78	0	0	690	316	46.0	7.6	8.0
10	0.000	0.000	0.000	2532	1890	60	60	0	130	60	480	0	0	0	0	0	0	4.8	0.0	0.0
11	27.670	39.240	66.910	7024	4260	760	240	1160	240	1150	590	5	118	1	0	649	454	36.0	9.7	13.2
12	59.740	66.630	126.370	10040	6200	750	310	640	250	2180	560	4	302	2	0	0	960	57.2	24.0	24.0
13	62.070	67.160	129.230	9908	6150	720	300	450	240	2200	500	3	318	1	0	0	960	58.4	24.0	24.0
14	60.670	67.980	128.650	10164	6220	820	300	620	230	2180	600	4	298	0	0	0	960	66.0	24.0	24.0
15	61.340	68.750	130.090	10180	6280	850	300	810	210	2180	540	4	339	2	0	0	960	63.6	24.0	24.0
16	13.370	15.260	28.630	6296	3670	310	140	0	150	1670	490	0	89	0	0	564	310	41.0	7.8	7.5
17	0.000	0.000	0.000	4048	2360	50	50	0	140	1080	490	0	0	0	0	0	0	4.8	0.0	0.0
18	38.330	0.000	38.330	7284	3960	760	250	860	220	1740	570	5	62	1	1	551	270	28.4	13.6	0.0
19	58.600	0.000	58.600	8728	4740	880	310	730	250	2160	580	6	127	1	0	0	480	36.5	24.0	0.0
20	63.830	0.000	63.830	8840	4850	890	320	840	250	2160	590	5	163	2	0	0	480	40.8	24.0	0.0
21	55.660	0.000	55.660	8752	4710	920	320	1010	250	2150	600	6	146	1	0	0	480	43.0	24.0	0.0
22	56.410	22.190	78.600	9004	5110	840	340	1250	260	2170	510	7	135	3	0	985	638	53.6	22.9	6.7
23	37.170	68.070	105.240	9272	5680	560	310	0	170	2190	490	1	214	0	0	135	828	44.2	17.3	24.0
24	0.000	67.340	67.340	8140	4260	990	290	0	180	2060	490	2	141	0	1	0	480	44.4	0.0	24.0
25	0.000	65.160	65.160	8768	4480	1260	310	740	240	2080	600	4	157	1	2	0	480	55.3	0.0	24.0
26	0.000	67.070	67.070	8832	4840	1230	320	490	250	1820	570	4	174	1	0	0	480	32.8	0.0	24.0
27	0.000	67.300	67.300	7812	4770	1060	310	280	240	1110	510	4	168	1	0	0	480	31.6	0.0	24.0
28	22.640	68.800	89.440	8516	5230	740	310	0	250	1590	590	3	159	1	0	1195	648	32.3	8.5	24.0
29	61.350	68.410	129.760	9976	6050	750	330	470	250	2230	590	5	288	2	0	0	960	65.4	24.0	24.0
30	62.890	14.060	76.950	8644	4840	720	320	0	170	2220	510	2	169	0	0	238	626	43.1	24.0	7.2
31	62.200	0.000	62.200	7824	4080	680	300	0	160	2200	510	1	126	0	0	0	480	30.9	24.0	0.0
最 大	63.830	68.750	131.200	11144	6490	1670	340	1880	320	2230	600	7	362	3	2	1195	1112	66.3	24.0	24.0
最 小	0.000	0.000	0.000	2532	1890	50	50	0	130	60	470	0	0	0	0	0	0	4.8	0.0	0.0
平 均	38.544	41.764	80.308	8425	4915	850	274	614	217	1811	542	4	188	1	0	240	616	44.2	15.4	15.1
合 計	1194.860	1294.690	2489.550	261188	152350	26360	8490	19040	6720	56140	16800	110	5835	30	5	7432	19088	1370.9	477.5	467.8

1号炉運転日数	25 日
2号炉運転日数	24 日

共 通 月 報

須賀川地方衛生センター
ごみ処理施設

2014年 9月

日 付	ご み 焼 却 量			電 力 量								用 水 使 用 量				灯 油 使用量	消石灰 使用量	キレート 使用量	運転時間	
	1号炉	2号炉	合 計	電力量	プラント 動力	建 築 動力	照明	管理棟 動力	管理棟 照 明	排ガス 高度処理 施設	浸出水 処 理 施設	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t	kWh	kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3		kg	リットル	H	H
1	58.350	20.160	78.510	8808	4910	710	330	250	240	2230	600	3	159	1	0	469	603	33.0	24.0	6.3
2	62.700	68.510	131.210	9916	6120	640	290	460	250	2230	580	4	302	2	1	0	960	52.0	24.0	24.0
3	63.700	68.590	132.290	9764	6380	320	290	0	250	2240	500	2	327	1	0	0	960	52.7	24.0	24.0
4	63.510	68.230	131.740	9852	6060	610	320	0	220	2220	600	4	287	1	0	0	960	52.7	24.0	24.0
5	61.950	68.740	130.690	10348	6190	1050	310	680	270	2200	550	5	292	1	0	0	960	55.6	24.0	24.0
6	13.280	14.150	27.430	6036	3530	210	140	0	150	1620	540	0	90	0	0	816	295	31.4	7.3	7.3
7	0.000	0.000	0.000	3996	2200	40	60	0	140	1140	540	0	0	0	0	0	0	4.8	0.0	0.0
8	0.000	40.250	40.250	6424	3690	430	270	240	230	1380	630	5	74	1	0	568	259	27.2	0.0	13.1
9	0.000	67.790	67.790	7084	4500	550	330	440	250	1110	560	4	167	1	0	0	480	26.9	0.0	24.0
10	0.000	67.780	67.780	7752	4790	850	330	80	240	1100	620	5	159	2	0	0	475	26.8	0.0	24.0
11	0.000	65.890	65.890	7232	4490	640	320	240	230	1110	640	6	191	1	1	0	480	29.2	0.0	24.0
12	0.000	68.660	68.660	6916	4460	350	330	50	230	1120	620	4	156	1	0	0	480	28.1	0.0	24.0
13	0.000	70.090	70.090	6792	4390	390	310	0	150	1120	540	2	179	0	0	0	480	24.6	0.0	24.0
14	0.000	69.000	69.000	6764	4380	380	300	0	160	1110	540	1	156	1	0	0	480	25.1	0.0	24.0
15	0.000	68.870	68.870	6676	4490	210	290	0	170	1120	550	1	193	0	0	0	480	28.0	0.0	24.0
16	29.140	68.170	97.310	8004	5050	350	310	30	230	1630	630	4	219	1	0	621	663	33.9	9.3	24.0
17	66.790	68.080	134.870	9588	6180	200	310	0	220	2240	610	3	348	1	0	0	960	41.9	24.0	24.0
18	67.390	67.680	135.070	9672	6250	220	290	0	220	2250	620	3	341	2	0	0	960	45.2	24.0	24.0
19	64.460	66.500	130.960	9360	6110	70	340	0	250	2250	560	3	342	1	0	0	960	46.5	24.0	24.0
20	0.000	0.000	0.000	1924	1360	20	40	0	70	200	300	0	0	0	0	0	0	2.6	0.0	0.0
21	0.000	0.000	0.000	2560	1840	40	80	0	120	60	550	0	0	0	0	0	0	4.8	0.0	0.0
22	39.400	0.000	39.400	5304	3330	360	220	0	190	730	640	4	78	1	0	293	265	21.8	13.4	0.0
23	66.980	0.000	66.980	6968	4380	520	300	0	180	1170	540	1	180	0	0	0	480	20.2	24.0	0.0
24	65.380	0.000	65.380	6904	4500	360	310	0	220	1160	550	2	181	1	0	0	480	21.8	24.0	0.0
25	67.100	0.000	67.100	6888	4470	280	320	0	220	1150	620	3	175	1	1	0	480	22.8	24.0	0.0
26	66.950	0.000	66.950	6896	4480	280	320	0	240	1170	620	5	196	2	0	0	480	24.1	24.0	0.0
27	67.810	0.000	67.810	6780	4430	290	300	0	180	1180	540	1	157	0	0	0	480	23.2	24.0	0.0
28	68.360	0.000	68.360	6768	4420	290	310	0	180	1180	540	1	179	0	0	0	480	22.6	24.0	0.0
29	66.120	0.000	66.120	6972	4520	280	340	0	240	1160	630	3	182	1	0	0	480	23.2	24.0	0.0
30	66.170	0.000	66.170	6984	4530	280	350	0	230	1160	610	4	198	1	0	0	480	24.7	24.0	0.0
31																				
最 大	68.360	70.090	135.070	10348	6380	1050	350	680	270	2250	640	6	348	2	1	816	960	55.6	24.0	24.0
最 小	0.000	0.000	0.000	1924	1360	20	40	0	70	60	300	0	0	0	0	0	0	2.6	0.0	0.0
平 均	37.518	36.571	74.089	7198	4548	374	279	82	206	1391	572	3	184	1	0	92	533	29.2	13.8	12.9
合 計	1125.540	1097.140	2222.680	215932	136430	11220	8360	2470	6170	41740	17170	83	5508	25	3	2767	16000	877.4	413.9	386.6

1号炉運転日数	19 日
2号炉運転日数	18 日

共 通 月 報

須賀川地方衛生センター
ごみ処理施設

2014年10月

日付	ごみ焼却量			電 力 量								用 水 使 用 量				灯 油 使用量	消石灰 使用量	キレート 使用量	運転時間	
	1号炉	2号炉	合 計	電力量	プラント 動力	建 築 動力	照明	管理棟 動力	管理棟 照 明	排ガス 高度処理 施設	浸出水 処 理 施設	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t	kWh	kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3	リットル	kg	リットル	H	H
1	60.190	30.240	90.430	8144	5160	430	350	0	310	1630	540	3	240	1	1	530	672	30.3	24.0	10.9
2	66.750	69.130	135.880	10052	6400	490	310	0	220	2250	560	3	352	1	0	0	960	48.8	24.0	24.0
3	67.060	69.920	136.980	9524	6220	260	290	0	240	2210	510	4	347	2	0	0	960	49.7	24.0	24.0
4	13.310	13.710	27.020	5364	3440	60	180	0	170	1230	440	1	94	0	0	453	290	26.0	7.4	7.0
5	0.000	0.000	0.000	2540	1940	40	70	0	130	40	460	0	0	0	2	0	0	4.8	0.0	0.0
6	0.000	41.400	41.400	5080	3610	70	230	0	190	670	480	3	66	1	1	398	262	21.1	0.0	13.2
7	0.000	67.320	67.320	6600	4540	80	320	0	230	1140	500	3	187	1	0	85	480	36.7	0.0	24.0
8	0.000	69.380	69.380	6680	4600	70	290	0	210	1140	530	3	165	1	0	0	480	28.1	0.0	24.0
9	0.000	68.820	68.820	6644	4530	80	320	0	210	1140	560	3	180	1	1	0	480	29.4	0.0	24.0
10	36.800	70.160	106.960	7968	5160	60	320	0	230	1860	540	3	240	1	0	836	718	40.4	12.0	24.0
11	69.100	14.850	83.950	7844	4770	70	300	0	170	2190	480	1	223	1	0	178	624	39.8	24.0	7.1
12	68.540	0.000	68.540	6204	4150	60	280	0	160	1200	490	0	182	0	0	0	480	24.4	24.0	0.0
13	67.930	0.000	67.930	6636	4570	80	300	0	180	1180	490	1	178	0	1	0	480	25.7	24.0	0.0
14	65.890	22.190	88.080	7304	4870	70	290	0	220	1540	500	3	214	1	0	479	611	29.0	24.0	6.7
15	67.430	68.290	135.720	9476	6210	70	310	0	210	2290	560	2	383	1	1	0	960	48.5	24.0	24.0
16	64.460	68.000	132.460	9472	6150	120	300	0	220	2300	560	3	322	1	1	0	960	51.1	24.0	24.0
17	67.880	68.490	136.370	9516	6150	190	320	20	260	2300	530	3	365	1	1	0	960	59.3	24.0	24.0
18	39.860	70.540	110.400	9120	5630	540	290	0	170	2120	490	1	292	0	0	200	811	52.9	16.5	24.0
19	0.000	14.790	14.790	4068	2740	190	140	0	160	500	490	0	45	0	3	402	144	24.0	0.0	7.1
20	0.000	39.560	39.560	5088	3410	220	230	0	240	680	540	4	88	1	1	427	262	16.5	0.0	13.2
21	0.000	67.780	67.780	7216	4480	500	290	0	240	1220	690	4	181	1	0	296	480	33.9	0.0	24.0
22	63.530	66.180	129.710	9324	5940	130	320	40	230	2290	610	2	323	1	0	614	950	43.4	23.6	24.0
23	63.680	51.800	115.480	9156	5680	130	320	40	250	2320	670	3	276	2	1	0	960	48.8	24.0	18.8
24	66.650	45.780	112.430	8892	5510	130	300	0	240	2320	590	3	267	1	0	428	960	34.2	24.0	15.1
25	13.030	13.520	26.550	5304	3380	110	140	0	140	1090	580	0	65	0	1	498	274	21.3	6.8	6.8
26	0.000	0.000	0.000	2600	1790	100	70	0	140	70	590	0	0	0	2	0	0	4.8	0.0	0.0
27	38.900	0.000	38.900	5280	3490	130	220	0	210	740	670	4	103	1	2	429	255	23.5	12.9	0.0
28	67.070	0.000	67.070	6860	4500	180	280	190	200	1210	660	3	181	0	1	0	480	24.1	24.0	0.0
29	67.550	46.070	113.620	8536	5430	170	310	40	220	2010	580	2	253	2	1	521	781	33.1	24.0	15.2
30	66.990	68.650	135.640	9620	6110	170	320	40	250	2330	660	3	358	1	0	0	960	46.9	24.0	24.0
31	67.090	69.170	136.260	9488	6100	170	300	20	230	2300	580	3	325	1	0	0	960	50.9	24.0	24.0
最 大	69.100	70.540	136.980	10052	6400	540	350	190	310	2330	690	4	383	2	3	836	960	59.3	24.0	24.0
最 小	0.000	0.000	0.000	2540	1790	40	70	0	130	40	440	0	0	0	0	0	0	4.8	0.0	0.0
平 均	40.958	41.798	82.756	7277	4731	167	268	13	209	1533	553	2	210	1	1	219	602	33.9	14.9	14.7
合 計	1269.690	1295.740	2565.430	225600	146660	5170	8310	390	6480	47510	17130	71	6495	25	21	6774	18654	1051.4	463.1	457.0

1号炉運転日数	22 日
2号炉運転日数	25 日

共 通 月 報

須賀川地方衛生センター
ごみ処理施設

2014年11月

日 付	ご み 焼 却 量			電 力 量								用 水 使 用 量				灯 油 使用量	消石灰 使用量	キレート 使用量	運転時間	
	1号炉	2号炉	合 計	電力量	プラント 動 力	建 築 動 力	照明	管理棟 動 力	管理棟 照 明	排ガス 高度処理 施 設	浸出水 処 理 施 設	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t	kWh	kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3	リットル	kg	リットル	H	H
1	14.130	14.060	28.190	5424	3470	120	140	40	130	1110	580	0	95	0	0	461	287	27.5	7.2	7.0
2	0.000	0.000	0.000	2664	1870	120	60	90	130	50	560	0	0	0	0	0	0	4.8	0.0	0.0
3	0.000	37.940	37.940	4932	3290	130	240	60	190	690	580	1	80	0	0	459	248	18.5	0.0	12.5
4	0.000	68.550	68.550	6820	4500	160	290	40	200	1150	670	3	196	1	0	0	480	32.0	0.0	24.0
5	45.880	68.060	113.940	8748	5630	170	310	50	240	2010	600	2	269	1	0	692	781	40.0	15.1	24.0
6	63.620	66.740	130.360	9452	5970	180	320	70	220	2290	650	3	348	1	1	0	953	49.6	24.0	24.0
7	66.130	66.560	132.690	9456	6020	170	310	50	250	2320	610	3	325	1	0	0	960	52.1	24.0	24.0
8	14.070	14.170	28.240	5972	3450	120	150	0	130	1660	580	1	90	0	2	404	277	23.8	6.8	6.9
9	0.000	0.000	0.000	3992	2060	100	60	0	130	1190	580	0	0	0	2	0	0	4.8	0.0	0.0
10	0.000	40.280	40.280	6564	3660	150	240	50	220	1820	670	3	65	1	1	459	265	18.2	0.0	13.4
11	0.000	67.830	67.830	7144	4090	170	330	50	210	1870	660	4	196	1	0	0	480	31.1	0.0	24.0
12	0.000	68.190	68.190	5744	3490	170	330	70	250	1130	590	2	185	1	0	0	480	28.6	0.0	24.0
13	0.000	68.280	68.280	6076	3490	440	330	60	210	1130	660	3	161	0	1	0	480	43.1	0.0	24.0
14	0.000	68.590	68.590	6300	3840	360	340	90	240	1140	580	4	180	2	1	0	480	33.4	0.0	24.0
15	0.000	14.120	14.120	4556	3210	120	160	0	160	490	570	0	45	0	0	265	141	15.0	0.0	6.9
16	0.000	0.000	0.000	3196	2390	100	70	0	150	60	590	0	0	0	1	0	0	4.8	0.0	0.0
17	39.380	42.440	81.820	7232	4610	250	240	120	230	1440	670	3	148	1	1	1189	543	21.6	13.1	14.3
18	67.750	69.680	137.430	10024	6120	600	310	160	210	2310	640	3	362	0	0	0	960	44.7	24.0	24.0
19	67.370	69.510	136.880	9780	6170	350	320	120	350	2330	570	2	318	2	1	0	960	44.3	24.0	24.0
20	66.520	68.240	134.760	9820	6240	180	340	130	490	2350	660	4	314	1	0	0	960	46.6	24.0	24.0
21	67.360	67.530	134.890	9616	6130	180	330	110	470	2350	600	3	343	1	0	0	960	47.1	24.0	24.0
22	14.040	14.000	28.040	5968	3470	120	150	0	210	1650	560	0	73	0	2	308	281	26.8	7.0	6.9
23	0.000	0.000	0.000	3712	1990	100	70	0	110	980	580	0	0	0	2	0	0	4.8	0.0	0.0
24	36.350	0.000	36.350	6088	3500	170	260	80	330	1580	560	2	86	0	1	689	248	17.7	12.5	0.0
25	67.770	0.000	67.770	6972	4560	180	340	150	460	1200	660	4	158	1	1	0	480	21.0	24.0	0.0
26	67.870	0.000	67.870	6492	4110	190	370	170	470	1210	580	2	199	1	1	1	480	24.4	24.0	0.0
27	67.340	0.000	67.340	5948	3520	180	370	170	480	1210	650	3	155	1	2	0	480	23.2	24.0	0.0
28	67.390	0.000	67.390	5940	3570	180	360	90	470	1200	610	3	177	1	0	0	480	40.0	24.0	0.0
29	14.250	0.000	14.250	4240	2750	120	170	0	220	640	560	7	58	0	2	210	143	15.1	7.1	0.0
30	0.000	0.000	0.000	3264	2500	100	70	0	140	50	550	9	0	0	2	0	0	4.8	0.0	0.0
31																				
最大	67.870	69.680	137.430	10024	6240	600	370	170	490	2350	670	9	362	2	2	1189	960	52.1	24.0	24.0
最小	0.000	0.000	0.000	2664	1870	100	60	0	110	50	550	0	0	0	0	0	0	4.8	0.0	0.0
平均	28.241	33.159	61.400	6405	3989	189	246	67	257	1354	606	2	154	1	1	171	443	27.0	10.3	11.9
合計	847.220	994.770	1841.990	192136	119670	5660	7380	2020	7700	40610	18130	74	4626	18	24	5137	13287	809.4	308.8	355.8

1号炉運転日数	17 日
2号炉運転日数	19 日

共 通 月 報

須賀川地方衛生センター
ごみ処理施設

2014年12月

日付	ごみ焼却量			電 力 量								用 水 使 用 量				灯 油 使用量	消石灰 使用量	キレート 使用量	運転時間	
	1号炉	2号炉	合 計	電力量	プラント 動力	建 築 動力	照明	管理棟 動力	管理棟 照 明	排ガス 高度処理 施設	浸出水 処 理 施設	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t	kWh	kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3	リットル	kg	リットル	H	H
1	26.990	40.400	67.390	6500	4300	170	260	130	390	1170	580	8	108	1	1	1047	431	16.7	8.7	13.3
2	67.760	71.470	139.230	9656	6160	180	350	140	460	2280	650	4	347	1	0	0	964	39.7	24.0	24.0
3	67.890	70.530	138.420	9572	6130	180	350	150	420	2310	560	2	367	1	0	0	1205	44.0	24.0	24.0
4	68.010	69.350	137.360	10008	6090	540	370	200	450	2300	670	8	307	1	0	0	1205	48.2	24.0	24.0
5	67.010	70.830	137.840	10148	6330	600	330	170	430	2270	570	3	346	1	1	0	968	47.4	24.0	24.0
6	14.010	15.160	29.170	5440	3500	180	140	0	220	1050	560	1	69	0	1	482	285	26.5	7.1	7.0
7	0.000	0.000	0.000	2668	1910	100	70	0	130	60	550	0	0	0	2	0	0	4.8	0.0	0.0
8	0.000	40.210	40.210	5392	3570	180	260	200	410	690	660	4	82	2	1	518	255	21.6	0.0	13.2
9	6.950	68.950	75.900	7168	4750	180	340	190	460	1290	570	3	188	1	0	535	509	30.2	1.6	24.0
10	51.420	70.750	122.170	9312	5830	180	340	180	430	2350	570	2	298	0	0	228	888	34.4	20.3	24.0
11	0.000	70.260	70.260	7576	4300	180	350	180	470	2070	650	4	185	2	1	0	480	32.0	0.0	24.0
12	0.000	68.650	68.650	6264	4080	180	330	150	470	1130	510	3	171	1	0	0	480	25.4	0.0	24.0
13	0.000	14.500	14.500	4212	2990	150	160	0	230	480	430	1	43	0	2	237	139	14.8	0.0	6.9
14	0.000	0.000	0.000	2964	2290	140	60	0	140	60	420	0	0	0	2	0	0	4.8	0.0	0.0
15	26.760	39.780	66.540	6568	4220	190	260	190	390	1260	610	3	122	1	1	1408	426	17.6	8.7	12.8
16	68.060	70.780	138.840	9648	6250	190	330	170	440	2340	520	3	372	1	0	0	960	43.2	24.0	24.0
17	68.590	72.020	140.610	9516	6260	180	340	180	450	2310	380	2	343	1	0	0	960	43.4	24.0	24.0
18	67.920	71.010	138.930	10148	6430	430	350	170	440	2330	580	3	340	1	0	0	960	42.2	24.0	24.0
19	68.810	71.280	140.090	10320	6590	600	340	160	490	2350	390	4	320	2	1	0	960	47.0	24.0	24.0
20	14.460	14.300	28.760	4840	3030	190	150	0	190	1020	460	0	94	0	0	489	275	26.4	6.8	6.8
21	0.000	0.000	0.000	3248	2360	200	70	0	130	50	580	0	0	0	0	0	0	4.8	0.0	0.0
22	38.870	0.000	38.870	5868	3850	240	290	230	370	760	700	3	66	0	0	802	254	17.0	12.8	0.0
23	66.740	0.000	66.740	7388	4960	170	340	80	470	1290	580	1	164	1	0	59	480	18.7	24.0	0.0
24	64.090	69.490	133.580	10204	6720	180	360	180	460	2310	590	3	332	1	0	349	943	38.0	24.0	23.3
25	58.070	62.250	120.320	10056	6430	190	370	200	450	2320	710	3	300	1	0	0	1027	44.0	24.0	24.0
26	47.200	68.520	115.720	9840	6280	180	380	190	470	2350	610	4	317	2	0	271	1200	46.5	17.9	24.0
27	13.960	14.330	28.290	5992	4040	130	170	0	220	1290	370	0	82	0	1	441	303	30.4	7.1	7.0
28	0.000	0.000	0.000	2992	2400	100	60	0	120	60	370	0	0	0	1	0	0	4.8	0.0	0.0
29	33.880	33.340	67.220	6640	4530	120	310	20	370	1300	370	1	148	0	1	1075	441	21.6	11.7	10.6
30	66.750	68.080	134.830	10160	6870	170	330	80	380	2370	360	0	388	0	0	0	960	49.6	24.0	24.0
31	14.150	14.410	28.560	5768	4060	140	160	0	220	1060	370	0	129	0	1	438	284	25.1	7.1	7.0
最大	68.810	72.020	140.610	10320	6870	600	380	230	490	2370	710	8	388	2	2	1408	1205	49.6	24.0	24.0
最小	0.000	0.000	0.000	2668	1910	100	60	0	120	50	360	0	0	0	0	0	0	4.8	0.0	0.0
平均	35.108	43.247	78.355	7293	4758	217	268	114	360	1493	532	2	194	1	1	270	588	29.4	12.8	15.1
合計	1088.350	1340.650	2429.000	226076	147510	6740	8320	3540	11170	46280	16500	73	6028	22	17	8379	18242	910.8	397.8	467.7

1号炉運転日数	23 日
2号炉運転日数	25 日

共 通 月 報

須賀川地方衛生センター
ごみ処理施設

2015年 1月

日 付	ご み 焼 却 量			電 力 量								用 水 使 用 量				灯 油 使用量 リットル	消石灰 使用量 kg	キレート 使用量 リットル	運転時間	
	1号炉	2号炉	合 計	電力量	プラント 動力	建 築 動力	照明	管理棟 動力	管理棟 照 明	排ガス 高度処理 施設 kWh	浸出水 処 理 施設 kWh	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t	kWh	kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3				H	H
1	0.000	0.000	0.000	3048	2450	120	60	0	120	50	370	0	0	0	1	0	0	4.8	0.0	0.0
2	0.000	0.000	0.000	3096	2490	120	60	0	130	60	370	0	0	0	3	0	0	4.8	0.0	0.0
3	0.000	0.000	0.000	3652	3050	120	70	0	130	50	380	0	0	0	0	0	0	4.8	0.0	0.0
4	36.000	39.850	75.850	7352	5110	170	230	0	300	1450	370	0	165	0	0	1070	498	26.8	12.1	13.1
5	64.370	66.660	131.030	10292	6810	200	350	200	430	2390	510	3	389	1	0	80	960	51.3	24.0	24.0
6	66.800	69.620	136.420	10400	6790	190	350	180	460	2360	680	2	393	1	0	0	960	53.8	24.0	24.0
7	67.240	69.820	137.060	10452	6820	190	340	180	470	2380	680	2	375	1	0	0	960	50.7	24.0	24.0
8	67.360	69.430	136.790	10256	6750	180	330	180	430	2390	580	2	357	1	1	0	960	52.6	24.0	24.0
9	66.430	66.350	132.780	10400	6740	180	360	170	460	2390	700	3	371	1	0	0	960	50.8	24.0	24.0
10	13.310	13.860	27.170	5876	3960	120	150	0	200	1050	570	0	69	0	0	344	263	28.6	6.5	6.5
11	0.000	0.000	0.000	3244	2450	100	70	0	110	60	580	0	0	0	1	0	0	4.8	0.0	0.0
12	36.600	0.000	36.600	5620	3830	170	260	170	310	740	580	1	65	0	0	675	240	15.5	12.1	0.0
13	66.600	0.000	66.600	7736	5120	280	350	180	450	1260	700	3	176	1	0	183	480	21.9	24.0	0.0
14	67.810	0.000	67.810	7728	5200	280	340	190	460	1260	590	3	195	1	1	0	480	26.9	24.0	0.0
15	65.400	51.740	117.140	9656	6330	190	350	190	440	2090	670	3	264	1	0	388	827	47.1	24.0	17.5
16	66.470	68.520	134.990	10136	6590	180	360	160	440	2300	670	3	325	1	0	0	960	51.5	24.0	24.0
17	11.300	10.790	22.090	5540	3870	120	150	0	220	840	530	0	77	0	1	901	276	31.2	7.1	6.5
18	0.000	0.000	0.000	2964	2390	100	90	0	150	60	340	0	0	0	1	0	0	4.8	0.0	0.0
19	0.000	40.670	40.670	5688	3980	180	290	180	380	670	550	3	66	1	1	542	259	20.2	0.0	13.3
20	0.000	71.960	71.960	7620	5060	580	390	180	430	1080	450	5	184	1	1	101	480	30.0	0.0	24.0
21	0.000	72.380	72.380	7600	5040	600	400	180	430	1100	420	3	195	1	0	138	480	33.4	0.0	24.0
22	0.000	73.390	73.390	7576	5050	430	360	180	430	1100	580	4	180	0	0	0	480	32.5	0.0	24.0
23	0.000	72.290	72.290	7176	4860	200	400	200	470	1090	580	5	157	2	0	0	480	31.8	0.0	24.0
24	0.000	72.340	72.340	6980	4720	200	340	130	360	1120	570	1	174	0	0	0	480	32.2	0.0	24.0
25	0.000	15.060	15.060	4920	3510	140	190	50	200	500	570	2	44	0	1	186	141	17.4	0.0	7.0
26	0.000	43.600	43.600	5984	4120	180	280	180	390	700	670	4	105	1	1	420	273	20.1	0.0	13.8
27	0.000	70.050	70.050	7144	4860	200	390	130	430	1120	540	4	204	1	0	0	480	30.9	0.0	24.0
28	0.000	72.440	72.440	6832	4700	190	370	150	440	1130	390	3	189	1	1	0	480	32.2	0.0	24.0
29	0.000	71.770	71.770	7192	4890	210	380	220	410	1130	550	5	184	1	0	0	479	31.3	0.0	24.0
30	0.000	71.960	71.960	7296	5040	200	400	200	490	1130	480	5	196	1	0	0	480	32.8	0.0	24.0
31	0.000	72.950	72.950	6896	4800	190	340	0	340	1130	400	0	155	0	0	0	480	30.9	0.0	24.0
最 大	67.810	73.390	137.060	10452	6820	600	400	220	490	2390	700	5	393	2	3	1070	960	53.8	24.0	24.0
最 小	0.000	0.000	0.000	2964	2390	100	60	0	110	50	340	0	0	0	0	0	0	4.8	0.0	0.0
平 均	22.442	43.467	65.909	6979	4754	210	284	122	352	1167	536	2	169	1	0	162	461	29.3	8.2	14.9
合 計	695.690	1347.490	2043.180	216352	147380	6510	8800	3780	10910	36180	16620	69	5254	19	14	5028	14296	908.4	253.9	461.6

1号炉運転日数	13 日
2号炉運転日数	23 日

共 通 月 報

須賀川地方衛生センター
ごみ処理施設

2015年 2月

日 付	ご み 焼 却 量			電 力 量								用 水 使 用 量				灯 油 使用量 リットル	消石灰 使用量 kg	キレート 使用量 リットル	運転時間	
	1号炉	2号炉	合 計	電力量	プラント 動力	建 築 動力	照明	管理棟 動力	管理棟 照 明	排ガス 高度処理 施設	浸出水 処 理 施設	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t	kWh	kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3				H	H
1	0.000	15.160	15.160	4760	3520	140	190	0	190	510	390	1	45	0	1	174	138	17.9	0.0	6.8
2	0.000	41.480	41.480	5496	3950	190	270	190	380	690	370	5	86	2	1	767	259	21.9	0.0	13.2
3	0.000	48.480	48.480	6252	4410	240	450	190	430	940	200	3	126	0	0	574	351	29.5	0.0	17.6
4	0.000	71.540	71.540	7052	4790	440	380	210	480	1090	290	4	178	2	0	0	480	36.3	0.0	24.0
5	0.000	71.440	71.440	7248	4910	620	400	190	440	1080	210	3	195	1	0	0	480	40.3	0.0	24.0
6	0.000	71.070	71.070	7356	4840	520	370	200	430	1070	500	4	180	1	1	0	480	38.8	0.0	24.0
7	0.000	69.050	69.050	7184	4900	190	340	0	340	1120	610	0	181	0	0	0	480	42.5	0.0	24.0
8	0.000	52.920	52.920	6756	4600	170	280	0	310	1060	600	1	154	0	0	175	397	38.3	0.0	19.8
9	0.000	42.920	42.920	6212	4310	200	280	190	360	690	710	4	103	1	0	582	272	23.2	0.0	13.8
10	0.000	66.250	66.250	7192	5050	310	340	230	450	1060	380	3	162	1	0	142	480	34.4	0.0	24.0
11	0.000	70.210	70.210	6880	4990	170	330	70	370	1050	300	1	182	0	0	0	480	36.2	0.0	24.0
12	0.000	70.840	70.840	7084	5010	180	350	190	410	1100	410	2	198	1	0	1187	480	37.4	0.0	24.0
13	0.000	71.710	71.710	6996	4990	190	360	180	470	1100	320	4	181	1	0	2917	480	36.7	0.0	24.0
14	0.000	11.700	11.700	4080	3100	120	190	0	200	390	280	1	41	0	1	1453	125	19.2	0.0	6.2
15	0.000	0.000	0.000	2524	2040	100	70	0	110	20	280	0	0	0	2	0	0	4.8	0.0	0.0
16	41.890	0.000	41.890	5816	4020	180	280	200	370	760	550	4	73	2	1	606	271	10.2	13.7	0.0
17	70.500	0.000	70.500	7652	5250	200	380	190	410	1250	540	4	173	0	1	0	480	22.0	24.0	0.0
18	71.230	0.000	71.230	7936	5430	200	400	200	410	1240	620	3	196	1	0	81	480	25.0	24.0	0.0
19	70.840	0.000	70.840	7948	5540	190	420	200	430	1240	530	4	180	2	1	0	480	27.9	24.0	0.0
20	71.700	0.000	71.700	8012	5310	440	370	190	430	1240	590	4	197	1	1	80	480	27.1	24.0	0.0
21	71.710	0.000	71.710	7680	4970	590	320	0	330	1260	510	0	182	0	0	16	480	25.7	24.0	0.0
22	14.860	0.000	14.860	5188	3610	220	180	0	190	660	500	1	44	0	1	137	136	15.8	6.8	0.0
23	43.150	0.000	43.150	5628	3860	200	270	180	360	760	500	3	90	1	1	478	271	13.9	13.7	0.0
24	70.310	0.000	70.310	7148	4730	220	350	200	400	1220	600	4	183	1	0	0	480	25.3	24.0	0.0
25	71.060	0.000	71.060	7548	4820	590	350	190	380	1230	500	4	196	1	1	0	536	25.0	24.0	0.0
26	69.590	0.000	69.590	7608	5140	220	350	240	410	1240	610	2	185	1	1	79	480	24.0	24.0	0.0
27	70.850	0.000	70.850	7512	5130	240	370	270	430	1230	510	4	191	1	1	0	480	25.2	24.0	0.0
28	71.720	0.000	71.720	7332	5020	220	300	30	340	1250	500	0	201	1	0	0	480	26.1	24.0	0.0
29																				
30																				
31																				
最 大	71.720	71.710	71.720	8012	5540	620	450	270	480	1260	710	5	201	2	2	2917	536	42.5	24.0	24.0
最 小	0.000	0.000	0.000	2524	2040	100	70	0	110	20	200	0	0	0	0	0	0	4.8	0.0	0.0
平 均	28.908	27.670	56.578	6646	4580	268	319	140	366	984	461	3	147	1	1	337	390	26.8	9.8	9.6
合 計	809.410	774.770	1584.180	186080	128240	7490	8940	3930	10260	27550	12910	73	4103	22	15	9448	10916	750.6	274.1	269.4

1号炉運転日数	13 日
2号炉運転日数	14 日

共 通 月 報

須賀川地方衛生センター
ごみ処理施設

2015年 3月

日 付	ご み 焼 却 量			電 力 量								用 水 使 用 量				灯 油 使用量	消石灰 使用量	キレート 使用量	運転時間	
	1号炉	2号炉	合 計	電力量	プラント 動力	建 築 動力	照明	管理棟 動力	管理棟 照 明	排ガス 高度処理 施設	浸出水 処 理 施設	上 水	河川水	管理棟 上 水	管理棟 給 湯				1号炉	2号炉
	t	t	t	kWh	kWh	kWh	kWh	kWh	kWh	kWh	kWh	m3	m3	m3	m3	リットル	kg	リットル	H	H
1	71.230	0.000	71.230	7320	5030	200	320	0	340	1250	490	1	185	0	0	0	480	23.2	24.0	0.0
2	71.660	0.000	71.660	7656	5150	210	350	230	450	1230	670	4	189	1	1	78	480	28.2	24.0	0.0
3	70.560	0.000	70.560	7600	5170	210	340	200	430	1240	600	3	203	1	0	0	480	28.2	24.0	0.0
4	71.810	0.000	71.810	7476	5080	200	340	190	430	1220	590	3	210	1	1	0	480	25.3	24.0	0.0
5	72.260	0.000	72.260	7628	5110	210	370	200	470	1230	660	2	199	1	0	79	484	25.5	24.0	0.0
6	71.810	0.000	71.810	7568	5060	200	350	180	430	1250	670	4	199	1	1	0	720	27.1	24.0	0.0
7	71.970	0.000	71.970	7396	5020	180	330	0	330	1250	570	1	182	0	0	0	509	25.9	24.0	0.0
8	15.310	0.000	15.310	5428	3750	150	230	0	190	720	570	0	58	0	2	225	138	16.9	6.8	0.0
9																				
10																				
11																				
12																				
13																				
14																				
15																				
16																				
17																				
18																				
19																				
20																				
21																				
22																				
23																				
24																				
25																				
26																				
27																				
28																				
29																				
30																				
31																				
最 大	72.260	0.000	72.260	7656	5170	210	370	230	470	1250	670	4	210	1	2	225	720	28.2	24.0	0.0
最 小	15.310	0.000	15.310	5428	3750	150	230	0	190	720	490	0	58	0	0	0	138	16.9	6.8	0.0
平 均	64.576	0.000	64.576	7259	4921	195	329	125	384	1174	603	2	178	1	1	48	471	25.0	21.9	0.0
合 計	516.610	0.000	516.610	58072	39370	1560	2630	1000	3070	9390	4820	18	1425	5	5	382	3771	200.3	174.8	0.0

1号炉運転日数	8 日
2号炉運転日数	0 日